



Wigan♥
Council

Request

I would like information regarding Leigh Market.

Could we please have details of if the vents that can be opened and closed within the roof of leigh indoor market are actually vents to circulate air or was they fitted for the purpose of in case of a fire ONLY.

Response

The Smoke Louvres situated in the roof of Leigh Market are for the purpose of Smoke extraction during a fire.

The current vents do not have automation for ventilation.

The vents that are being planned as part of the refurbishment of Leigh Market will be for both smoke extraction during a fire and ventilation.